

Fire Extinguisher Inspection Certificate APRIL 2024

This certificate confirms that we have completed the maintenance service of your fire equipment listed in accordance with BS 5306: Part 3: 2000

Extract from British Standard 5306-3: 2000

It is recommended that regular visual inspections of all portable fire extinguishers are carried out by the user or users representative, no less than monthly.

The Fire Safety Order 2005 suggest that good practice is to check for correct installation and apparent function on a weekly basis. Inspections should include checks that each extinguisher is located in the designated place, is unobstructed, visible and its operating instructions face outwards, has operating instructions which are clean and legible, is not obviously damaged, has a reading in the operable range or position of any pressure gauge or indicator fitted and has seals and tamper indicators which are not broken or missing.

The user should arrange for corrective action where necessary.

Registered business	Site address (if applicable)	Customer address
Firecheck North West Limited Firecheck House 9 Avon Road Culcheth Warrington Cheshire WA3 5DT		Croft Village Hall 5 Mustard Lane Croft Warrington Cheshire WA3 7DG

Fire Extinguishers					
		Result			
Location	Service Type	ID No.	PASS	FAIL	Comments
Entrance	9 Litre Gas/water	1	PASS		
Main Hall	6 Litre AFFF Foam	2	PASS		
Main Hall	6 Litre AFFF Foam	3		FAIL	
Main Hall	6 Litre AFFF Foam	4	PASS		
Main Hall	2 Kg Carbon Dioxide	13	PASS		
Stage	2 Kg Carbon Dioxide	5	PASS		
Kitchen	2 Kg Carbon Dioxide	6	PASS		
Kitchen	Fire Blanket	7	PASS		
Birch Hall	6 Litre AFFF Foam	8	PASS		
Kitchen Birch hall	2 Kg Carbon Dioxide	9	PASS		
Kitchen Birch Hall	Fire Blanket	10	PASS		NO ID SIGN

Front Boiler Room	2 Kg ABC Dry Powder	11	PASS		
Rear Boiler Room	2 Kg ABC Dry Powder	12	PASS		
12				1	



Engineer Name: Mike Schofield	Name:	Date: April 2024 Next Annual Service: APRIL 2025
---	--------------	--