

Emergency Lighting Inspection Certificate APRIL 2024

This certificate confirms that we have completed the maintenance service of your emergency lighting and certify that the said work for which we have been responsible complies to the best of our knowledge and belief with the recommendations of BS 5266-8: 2004, except for the variations, if any, stated on this certificate.

Extract from British Standard Emergency lighting testing.

BS EN 50172 / BS 5266-8 (Emergency escape lighting systems) defines the testing that should be performed on an emergency lighting system as follows: A brief functional test at least once each month

- A full duration test at least every year
- A visual inspection at least every year
- BS 5266-1 also advises that records of all tests and repairs should be kept in a log book

The user should arrange for corrective action where necessary.

Registered business	Site address (if applicable)	Customer address
Firecheck North West Limited Firecheck House 9 Avon Road Culcheth Warrington Cheshire WA3 5DT		Croft Village Hall 5 Mustard Lane Croft Warrington Cheshire WA3 7DG

Emergency Lighting

Location	Type/Size	ID No.	Result		Comments
			PASS	FAIL	
Main Entrance (External)	Bulkhead	1	PASS		
Main Entrance	Bulkhead	2	PASS		
WC Corridor	2D Bulkhead	3	PASS		
Ladies WC	Bulkhead	4	PASS		
Ladies WC	Bulkhead	5	PASS		
Gents WC	Bulkhead	6	PASS		
Gents WC	Bulkhead	7	PASS		
Main Hall	Bulkhead	8	PASS		
Main Hall	Bulkhead	9	PASS		
Main Hall	Bulkhead	10	PASS		
Main Hall	600 X 600 LED Panel	11	PASS		
Main Hall	600 X 600 LED Panel	12	PASS		
Main Hall	600 X 600 LED Panel	13	PASS		

Main Hall	600 X 600 LED Panel	14	PASS		
Main Hall	600 X 600 LED Panel	15	PASS		
Main Hall RH Exit	Bulkhead	16	PASS		
Main Hall RH Exit (External)	Bulkhead	17	PASS		
Main Hall LH Exit	Exit Box	18	PASS		
Main Hall LH Exit (External)	Bulkhead	19	PASS		
Birch Hall WC Corridor	Bulkhead	20	PASS		
Disabled WC	Downlight	21	PASS		
Ladies WC	Bulkhead	22	PASS		
Gents WC	Bulkhead	23	PASS		
Birch Hall WC Exit (External)	Bulkhead	24	PASS		
Birch Hall Kitchen	Bulkhead	25	PASS		
Birch Hall Kitchen Exit	Bulkhead	26	PASS		
Birch Hall Kitchen Exit (External)	Bulkhead	27	PASS		
Birch Hall	Bulkhead	28	PASS		
Birch Hall	Twin Spotlight	29	PASS		
Birch Hall Exit	Exit Box	30	PASS		
Birch Hall Exit (External)	Bulkhead	31	PASS		
Main Hall Kitchen	Exit Box	32	PASS		
Main Hall Kitchen (External)	Bulkhead	33	PASS		
33					

Engineer Name: Mike Schofield	Name:	Date: April 2024 Next Annual Service: APRIL 2025